



Fire Safety Application

Escambia County, Florida

Fire Safety Permit Number: _____

Building Permit Number: _____

Approved By: _____ Date: _____

Nature of Job:	<input type="checkbox"/> Hood Suppression	<input type="checkbox"/> Sprinkler System	<input type="checkbox"/> Underground Piping
----------------	---	---	---

Job Address:	Building or Unit Number:
Owner Name:	Phone Number:
Project Name:	
Name of Installer:	Phone Number:
Name of Company:	Phone Number:

<i>Please complete all sections below that may apply:</i>			
Sprinkler System: (Circle One)		Number of Fire Hydrants	
Partial (P) or Complete (C)		Number of Fire Department Hoses	
Standpipe System: (Circle One)		Number of Fire Pump Connections	
Class I, Class II, or Class III		Number of Underground Stub-Ins (ONLY)	
Number of Units		Number of Heads	
Number of Units Per Floor		Number of Hood Suppression Systems	
Number of Floors		Number of Garbage Chutes	
Total Square Feet		Number of Laundry Chutes	
		Number of Hose Cabinets	
		Number of Underground Fire Mains	
		Other:	

Additional Information:

NOTICE: No work shall be commenced until a permit has been secured. All work must be inspected before covering. At least twenty-four (24) hours notice must be given for inspection.

I hereby make application to perform the work as described herein. All Provisions of the Law shall be complied with whether they have been specified herein or not.

Applicant's Signature: _____ Date: _____

County License Number: _____ Escrow Account Number: _____



The following Wet Chemical System Plans Submittal Checklist is required information for wet chemical system permit review. Use of the form does not guarantee that plans will be accepted on the first submittal, but will aid in reducing the number of re-submittals required due to the lack of information or conflicting information being provided. **This checklist should not be considered to be all-inclusive. Additional information may be required. Use of this checklist will not eliminate the requirement for a good knowledge and understanding of NFPA 17A.**

For issuance of the wet chemical system permit and prior to any installation and inspection request, the following information and/or forms shall be completed, submitted and approved.

- Completed & approved permit application.**
- Include payment for permit fees.**
- Three (3) sets of shop drawings/plans.**

Any material installed or work performed prior to the issuance of a permit will be subject to two times the permit fee and/or required to be removed. A hard copy of the permit and an approved set of plans are required to be maintained on the job site at all times and must be on site prior to any worked being performed unless a limited early start request has been granted. Limited early start requests are considered on a case by case basis, are required to be submitted in writing on letter head and are not automatically granted.

- 6.1* Specifications.** Specifications for wet chemical fire extinguishing systems shall be drawn up with care under the supervision of a trained person and with the advice of the authority having jurisdiction.
- 6.1.1** The following items shall be included in the specifications:
 - (1) Designation of the authority having jurisdiction and indication of whether plans are required
 - (2) Statement that the installation conforms to this standard and meets the approval of the authority having jurisdiction
 - (3) Indication that only equipment that is referenced in the manufacturer's listed installation and maintenance manual or alternate suppliers' components that are listed for use with the specific extinguishing system shall be used
 - (4) Identification of special auxiliary devices acceptable to the system manufacturer and the authority having jurisdiction
 - (5) List of the specific tests, if any, that are required
 - (6) Identification of the hazard to be protected and including such information as physical dimensions, cooking appliances, energy sources for each appliance, and air handling equipment
- 6.2* Review and Certification.** Design and installation of systems shall be performed only by persons properly trained and qualified to design and/or install the specific system being provided. The installer shall provide certification to the authority having jurisdiction that the installation is in complete agreement with the terms of the listing and the manufacturer's instructions and/or approved design.
- 6.3 Plans.** Where plans are required, the responsibility for their preparation shall be entrusted only to trained persons.
- 6.3.1** The plans shall be drawn to an indicated scale or be suitably dimensioned and shall be reproducible.

Opposite side of this page is required to be completed and signed.



**FIRE PREVENTION DIVISION
PUBLIC SAFETY BUREAU**

**WET CHEMICAL SYSTEM
PLANS SUBMITTAL CHECKLIST
NFPA 17A (2009 EDITION)**

- 6.3.2** The plans shall contain sufficient detail to enable the authority having jurisdiction to evaluate the protection of the hazard(s).
- 6.3.3** The details on the system shall include the following:
 - (1) Size, length, and arrangement of connected piping
 - (2) Description and location of nozzles
- 6.3.4** Information shall be submitted pertaining to the following:
 - (1) The location and function of detection devices
 - (2) Operating devices
 - (3) Auxiliary equipment
 - (4) Electrical circuitry
- 6.3.5** Approval of Plans. Where plans are required, they shall be submitted to the authority having jurisdiction for approval before work starts.
- 6.3.6** Where field conditions necessitate any substantial change from the approved plan, the as-installed plans shall be submitted to the authority having jurisdiction for approval.

I attest that all required and applicable information noted above has been provided for review and approval and understand that inadequate or incorrect content is cause for permit denial

Signature of Contractor or Contractor's Representative

Date